



**Purchasing Department
901-B Texas St.
Denton, TX 76209
(940) 349-7100
www.dentonpurchasing.com**

ADDENDUM #2

IFB # 7460

U.S. 380 & Scripture Street Transmission Mains

**Issue Date: October 13, 2020
Response due Date and Time (Central Time):
Tuesday, October 20, 2020, 11:00 A.M. C.S.T**

IFB # 7460

ADDENDUM #2

The following are changes to the specification sheet:

1. Changes to unit price form (00 42 43). Attached new form “*ADDENDUM 2 – 7460 – Unit Price Form (00 42 43)*” must be used and submitted with bid proposal.

2. As directed by Mr. Frank Pugsley, Deputy Director, Water and Wastewater:

- a. Refer to the cover sheet of the plans
- b. Refer to the Project Manual -NCTCOG 4th Addition Amendments, Item 501.7 Ductile Iron Pressure Pipe (page 8 of 25; page 214 of the project manual)

Clarification/Change by the City: “Ductile iron Pipe shall have a zinc exterior coating (ISO 8179-1) and be exterior corrosion protected using 8 mil thick “V-bio” Enhanced polyethylene encasement (AWWA C105/A21.5)”. Apply this change to all occurrences in the Construction Plans and Project Manual.

NO OTHER CHANGES AT THIS TIME.

Please acknowledge this addendum on
BID FORM (00 41 00 -3) of the specifications document
when submitting a proposal.